



SURFACING MATERIAL	SURFACING REQUIREMENTS	BASE ROCK REQUIREMENTS
CONCRETE	6" OF 4000 PSI PORTLAND CEMENT CONCRETE	3" OF 1"-0" CRUSHED AGGREGATE
ASPHALT	4" OF ASPHALTIC CONCRETE PAVEMENT	6" OF 1"-0" CRUSHED AGGREGATE

**NOTES:**

1. SEE DETAIL DWG. NO. 312 FOR CULVERT REQUIREMENTS.
2. ALL SURFACE MATERIALS, BASE ROCK, AND TRENCH BACKFILL SHALL BE COMPACTED TO CITY STANDARDS.
3. ALL CONCRETE SHALL HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 4000 PSI.
4. ROADSIDE DITCHES SHALL NOT BE FILLED IN EXCEPT AT DRIVEWAY LOCATIONS WITH CULVERT.

CITY OF ALBANY, OREGON PUBLIC WORKS DEPARTMENT		
STANDARD DRIVEWAY APPROACH FOR UNIMPROVED STREETS		
NO SCALE	JULY 2005	NO. 311